



Garcilaso, 4 Baixos
08201 Sabadell
935 959 560

laboratori@analisiisreig.cat
www.analisiisreig.cat

Doctor ROSER REIG RIUS director of **INDUSTRIAL LAB R. REIG, S.L.** with CIF B65324238 and address Garcilaso 4 in Sabadell (Barcelona) Spain.

CERTIFIES:

That INDUSTRIAL LAB R. REIG, S.L. has obtained, on behalf of **SODECA, S.L.U**, a strain of MengoVirus vMCo CECT100000 from the Colección Española de Cultivos Tipo (Spanish Type Culture Collection).

Mengoviruses are non-enveloped RNA viruses, just like the test microorganisms mentioned in the standard. The MengoVirus belongs to the Picornaviridae family and the coronavirus, which causes the COVID-19 disease, belongs to the Coronaviridae. Both viruses are class IV viruses in the Baltimore system and they have positive sense single-stranded RNA. Single-stranded RNA is ultimately the target of the destructive action, therefore, the mengovirus has been used to certificate the SARS-CoV-2 disinfection tests, according to the adaptation of the UNE-EN 14476 standard (*Antiseptics and chemical disinfectants; quantitative suspension test for the evaluation of viricidal activity in medicine; test methods and requirements*) to evaluate the efficacy of the equipment:

UPT EC-CG | U PT AC-CG

that SODECA, S.L.U. commercializes, analyzing the air inoculated with the virus at the air exit of the machine before and after the treatment.

According to the tests carried out in the INDUSTRIAL LAB R. REIG, S.L. the tested equipment has demonstrated, from 10 minutes, an antiviral activity on inoculated viruses of 100%.

After 40 minutes of operation of the tested equipment **NO ozone has been detected** in the treated environment (**< 0.001 ppm**).

Sabadell, 21th July 2021



Garcilaso, 4 Baixos
08201 Sabadell
935 959 560

Doctor Roser Reig

Director



Generalitat de Catalunya
Departament de Salut
LABORATORI DE SALUT AMBIENTAL
I ALIMENTÀRIA: LSAA-155-01



agencia española de
medicamentos y
productos sanitarios



MINISTERIO
DE SANIDAD
Y CONSUMO

ÁREA DE CALIDAD SANITARIA DE LAS AGUAS. REGISTRO
S. G. DE SANIDAD AMBIENTAL Y SALUD LABORAL



Garcilaso, 4 Baixos
08201 Sabadell
935 959 560

laboratori@analisiisreig.cat
www.analisiisreig.cat

Doctor ROSER REIG RIUS director of **INDUSTRIAL LAB R. REIG, S.L.** with CIF B65324238 and address Garcilaso 4 in Sabadell (Barcelona) Spain,

CERTIFIES:

That INDUSTRIAL LAB R. REIG, S.L. has evaluated the efficiency of the equipment:

UPT EC-CG | U PT AC-CG

that **SODECA, S.L.U.** commercializes, analysing the environmental air: total aerobic bacteria and fungi, before and after the environmental treatment with the already mentioned equipment.

According to the tests carried out in the INDUSTRIAL LAB R. REIG, S.L. the tested equipment has showed a **reduction rate of 98,15%** at 40 minutes for the total aerobic bacteria. For fungi, the equipment has shown reduction rates of **96,67%** 40 minutes after starting its operation.

After 40 minutes of operation of the tested equipment **NO ozone has been detected** in the treated environment (**< 0.001 ppm**).

Sabadell, 21th July 2021



Garcilaso, 4 Baixos
08201 Sabadell
935 959 560

Doctor Roser Reig

Director



Generalitat de Catalunya
Departament de Salut
LABORATORI DE SALUT AMBIENTAL
I ALIMENTÀRIA: LSAA-155-01



agencia española de
medicamentos y
productos sanitarios
LABORATORIO DE CONTROL



GOBIERNO
DE ESPAÑA

MINISTERIO
DE SANIDAD
Y CONSUMO

ÁREA DE CALIDAD SANITARIA DE LAS AGUAS. REGISTRO
S. G. DE SANIDAD AMBIENTAL Y SALUD LABORAL